




Project Number: Sunny Falls Ranch
Project Name: Passive Solar & HR Heated Residence
Location: 19000 E. Evans Creek Rd.,
 Rogue River, OR 97537
Date: June 19, 2015
Prepared By: Robert Borst
 Borst Engineering & Construction
Floor Plan: Ground Floor

Circuit Information:

Total Length: 1,641 ft - hePEX 1/2"

Circuit	Length	Manifold	Tube Type
A-1	242	Manifold 1	1/2
A-2	219	Manifold 1	1/2
A-3	232	Manifold 1	1/2
A-4	224	Manifold 1	1/2
A-5	219	Manifold 1	1/2
A-6	209	Manifold 1	1/2
A-7	175	Manifold 1	1/2
A-8	120	Manifold 1	1/2



Note: Details of the tubing bend radius have been simplified for clarity. Consult tubing manufacturer for specific bend radius recommendations.
 Created Using LoopCAD 2015 15.0.0594 (2/6/2016)

Disclaimers

With the permission of the Air Conditioning Contractors of America ("ACCA"), material is reproduced from Manual J Residential Load Calculation (8th Edition) which is copyrighted by ACCA. The program and data are provided "as is" without warranty of any kind either expressed or implied. The entire risk as the quality and performance of the program and data is with you. In no event will ACCA be liable to you for any damages, including without limitation any lost profits, lost savings, or other incidental or consequential damages arising out of the use or inability to use this program or the data. © 2011 Air Conditioning Contractors of America. All Rights Reserved. www.acca.org

ACCA, Manual J and Powered by ACCA Manual J are registered trademarks of the Air Conditioning Contractors of America. All rights reserved.

Cold weather humidification, or some lifestyles that produce excessive moisture, may cause condensation to occur if the absolute humidity of the indoor air is too high for the momentary circumstances. Condensation can occur on surfaces or concealed within the structure, and can lead to mold, mildew, frost damage, and moisture damage. The software does not perform calculations for the estimation or detection of possible condensation problems, and it is the designers (i.e. software users) responsibility to do so independently if required. For guidance and additional cautions refer to ACCA Manual J 8th Edition, including Section 1-11 and Section 27.

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.



Robert Borst
 Borst Engineering & Construction
 19000 E. Evans Creek Rd.
 Rogue River, OR 97537
 Phone: 541-826-7222
 Email:sunnyfallsrb@gmail.com

Load Report
 Manual J8 Load Calculation
 Project #:Sunny Falls Ranch
 June 19, 2015

Project Information

Project #: Sunny Falls Ranch
 Name: Passive Solar & HR Heated Residence
 Location: 19000 E. Evans Creek Rd., Rogue River, OR 97537

Notes:

Manual J Load Summary

Total Heating: 18,811 Btu/hr

Total Sensible: 0 Btu/hr

Total Latent: 0 Btu/hr

Outdoor Conditions

Location: (User Specified) Rogue River,
 Evans Creek Valley, Oregon
 Elevation: 1550 ft
 Latitude: 42.4
 Dry Bulb: **Heating** 26.0 °F **Cooling** 95.0 °F
 Daily Range: High
 Wet Bulb: 66.0 °F

Indoor Conditions

	Heating	Cooling
Room Temp:	60 - 70 °F	
Design Temp Diff:	44.0 °F	20.0 °F
Humidity:	35	50
Moisture Diff (Grains):		-13.7

Infiltration

Method: Simple
 Stories: 1
 Construction: Tight
 Exposure Category: Three or Four Exposures
 Num Fireplaces: None
 Net Air Changes (Heat/Cool): 0.14 / 0.00
 Net Flow (Heat/Cool): 40 cfm / 0 cfm

Ventilation

	Heating	Cooling
Num Occupants:	2	
Type:	Heat Recovery	Type: Heat Recovery
ACH:	0.35	Outside Air: 0 cfm
Outside Air:	101 cfm	Sensible Eff: 50 %
Sensible Eff:	50 %	

Floorplan/Levels

Ground Floor	1,789 ft ²	Total Heated Area:	1,789 ft ²
		Total Cooled Area:	0 ft ²

Length = ft Area = ft² Temperature = °F Flowrate = USGPM Heat Loss = Btu/hr Unit Heat Loss = Btu/hr-ft² Rv = hr-ft²-°F/btu
 Head Loss = ft water RH = Radiant Floor Heating BB = Baseboard FA = Forced Air OTH = Other Heating SM = Snowmelt N = Not Heated

Created Using LoopCAD 2015 Uponor(US) (2/6/2016)
 Version:15.0.0594

Constructions**Walls**

Code	Description	U-Value	Area	Heating	Cooling
14D-24	Foam Concrete Matrix - R-22 to R-26; No Cavity Insulation; Plus Interior Finish	0.04	1,235	2,294	0
12A-0bw	Frame Wall or Partition; Wood Framing; No Cavity Insulation; Brick Veneer; Plus Interior Finish	0.25	127	160	0
12E-5sw	Frame Wall or Partition; Wood Framing; R-19 Insulation in 2 x 6 Stud Cavity; Stucco or Wood Siding; Plus Interior Finish	0.05	167	44	0
12E-5sw	Frame Wall or Partition; Wood Framing; R-19 Insulation in 2 x 6 Stud Cavity; Stucco or Wood Siding; Plus Interior Finish	0.05	249	539	0

Doors

Code	Description	U-Value	Area	Heating	Cooling
11P	Metal Door with Polyurethane Core	0.29	67	851	0
11P	Metal Door with Polyurethane Core	0.29	20	197	0

Floors

Code	Description	U-Value	Area	Heating	Cooling
22D-15-r	22D - Vertical Board Insulation Covers Slab Edge, Turns Under the Slab and Extends Four Feet Horizontally, any Floor Cover	0.07	23 (P)	120	0
22D-15-r	22D - Vertical Board Insulation Covers Slab Edge, Turns Under the Slab and Extends Four Feet Horizontally, any Floor Cover	0.07	38 (P)	291	0
22D-15-r	22D - Vertical Board Insulation Covers Slab Edge, Turns Under the Slab and Extends Four Feet Horizontally, any Floor Cover	0.07	103 (P)	1,170	0
22D-15-r	22D - Vertical Board Insulation Covers Slab Edge, Turns Under the Slab and Extends Four Feet Horizontally, any Floor Cover	0.07	32 (P)	130	0

Ceilings

Code	Description	U-Value	Area	Heating	Cooling
16C-38ml	FHA vented attic; No radiant barrier over ceiling or same type of air space behind an attic knee wall; Materials: Asphalt Shingles(a), Metal(m), Wood Shakes(w), Tar / Gravel(x), Membrane(z); Colors: Light(l), White(w);	0.03	1,789	2,017	0

Glazing

Windows


Code	Description	Exposure	U-Value	SHGC	Area	Heating	Cooling
10Bf	French Door with Double Pane Clear Glass and Insulated Fiberglass Frame, BlindsMedium45 (50%), 4', 1'-6" above., GreenGrass	S	0.48	0.39	34	727	0
1D-cf	Double pane operable window or sliding glass door, with Clear Glass - Insulated Fiberglass Framing, BlindsMedium45 (50%), 4', 1'-6" above., GreenGrass	E	0.49	0.56	50	1,073	0
1D-cf	Double pane operable window or sliding glass door, with Clear Glass - Insulated Fiberglass Framing, BlindsMedium45 (50%), 4', 1'-6" above., GreenGrass	N	0.49	0.56	10	165	0
1D-cf	Double pane operable window or sliding glass door, with Clear Glass - Insulated Fiberglass Framing, BlindsMedium45 (50%), 4', 1'-6" above., GreenGrass	S	0.49	0.56	200	4,302	0
1D-cf	Double pane operable window or sliding glass door, with Clear Glass - Insulated Fiberglass Framing, BlindsMedium45 (50%), 4', 1'-6" above., GreenGrass	N	0.49	0.56	30	646	0

Load Breakdown

Name	Heating	Sensible	Latent
Windows*	6,913	0	
Skylights*	0	0	
Doors	1,048	0	
Walls	3,038	0	
Below Grade Walls	0		
Ceilings	2,017	0	
Floors	0	0	
Infiltration	1,816	0	0
Internal		0	0
Other	0		
Duct Loads	0	0	0
Ventilation	2,270	0	0
Humidification	0		
Piping Load	0		
Radiant Backloss	1,710		
Blower Heat		0	
AED*		0	
Total	18,811	0	0
Total Area	1,789 ft ²	0 ft ²	

*Average Load Procedure

Heating Load Breakdown



Heating Zones

Zone	Area	Room Temp	Total Load
Zone 101	1,213	70	12,866
Zone 102	327	70	3,202
Zone 103	137	70	1,317
Zone 104	112	60	1,427

Heating Rooms

Room	Area	Room Temp	Total Load
Great Room Zone	1,213	70	12,866
Master Bathroom Zone	137	70	1,317
Master Bedroom Zone	327	70	3,202
Utility Room Zone	112	60	1,427

Design Locaton

Location:	Rogue River, Evans Creek Valley	Altitude:	1550' ft
Province/State:	Oregon	Latitude:	42.4
Country:	United States	Wet Bulb Temperature:	66.0 °F
Outdoor Heating Design Temp:	26.0 °F	Daily Range:	High
Outdoor Cooling Design Temp:	95.0 °F		
MJ8Custom			

Disclaimers

With the permission of the Air Conditioning Contractors of America ("ACCA"), material is reproduced from Manual J Residential Load Calculation (8th Edition) which is copyrighted by ACCA. The program and data are provided "as is" without warranty of any kind either expressed or implied. The entire risk as the quality and performance of the program and data is with you. In no event will ACCA be liable to you for any damages, including without limitation any lost profits, lost savings, or other incidental or consequential damages arising out of the use or inability to use this program or the data. © 2011 Air Conditioning Contractors of America. All Rights Reserved. www.acca.org

ACCA, Manual J and Powered by ACCA Manual J are registered trademarks of the Air Conditioning Contractors of America. All rights reserved.

Cold weather humidification, or some lifestyles that produce excessive moisture, may cause condensation to occur if the absolute humidity of the indoor air is too high for the momentary circumstances. Condensation can occur on surfaces or concealed within the structure, and can lead to mold, mildew, frost damage, and moisture damage. The software does not perform calculations for the estimation or detection of possible condensation problems, and it is the designers (i.e. software users) responsibility to do so independently if required. For guidance and additional cautions refer to ACCA Manual J 8th Edition, including Section 1-11 and Section 27.

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.



Robert Borst
 Borst Engineering & Construction
 19000 E. Evans Creek Rd.
 Rogue River, OR 97537
 Phone: 541-826-7222
 Email: sunnyfallsrb@gmail.com

Form J1
 Manual J8 Load Calculation
 Project #: Sunny Falls Ranch
 June 19, 2015

Project Information

Project #: Sunny Falls Ranch
 Name: Passive Solar & HR Heated Residence
 Location: 19000 E. Evans Creek Rd., Rogue River, OR 97537

Notes:

Form J1 (Summer)																
1		Name of Room				Passive Solar & HR Heated Residence				Entire House						
2		Running Feet of Exposed Wall								165						
3		Ceiling Height (Ft) and Gross Wall Area (SqFt)				9.7				2,189						
4		Room Dimensions (Ft) and Floor Plan Area (SqFt)								1,789						
5		Ceiling Slope (Deg.) and Gross Ceiling Area (SqFt)								1,789						
		Type of Exposure		Construction Number		Panel Faces		HTM		Area or Length		Btuh				
								Htg.		Clg.		Heating		S-Clg.	L-Clg.	
6a	Windows and Glass Doors	a	10Bf	S	21.12	34.41	727									
		b	1D-cf	E	21.56	49.79	1,073									
		c	1D-cf	N	16.66	9.89	165									
		d	1D-cf	S	21.56	200	4,302									
		e	1D-cf	N	21.56	29.95	646									
6b	Skylights	a														
7	Wood and Metal Doors	a	11P		12.76	66.67	851									
		b	11P		9.86	20.00	197									
8	Above Grade Walls and Partitions	a	14D-24		1.50	1,235	2,294									
		b	12A-0bw(Partition)			127	160									
		c	12E-5sw(Partition)			167	44									
		d	12E-5sw(Partition)			249	539									
9	Below Grade Walls	a														
10	Ceilings	a	16C-38ml			1,789	2,017									
11	Floors	a	22D-15-r		0.88	23 (F)	120									
		b	22D-15-r		0.89	38 (F)	291									
		c	22D-15-r		0.96	103 (F)	1,170									
		d	22D-15-r		1.16	32 (F)	130									
12	Infiltration	Heating Load (Btuh)		Effect ACH		0.140		WAR 1.0		1,816						
		Sensible Load (Btuh)														
		Latent Load (Btuh)														
13	Internal	a	Occupants at 230 and 200 Btuh				2									
		b	Scenario Number				Def									
		c	Default Adjustments													
		d	Custom Appliances													
		e	Plants													
Other		User specified additional loads														
14		Subtotals		Sum lines 6 through 13						16,541						
15		Duct Loads		EHLF & ESGF												
				ELG												
16		Ventilation Loads		Vent Cfm		101 / 0		E Cfm		101 / 0		2,270				
17		Winter Humidification Load						Gal/Day								
18		Piping Load														
19		Blower Heat														
20		AED Excursion														
21		Total Load		Sum lines 13 through 19						18,811						

Disclaimers

With the permission of the Air Conditioning Contractors of America ("ACCA"), material is reproduced from Manual J Residential Load Calculation (8th Edition) which is copyrighted by ACCA. The program and data are provided "as is" without warranty of any kind either expressed or implied. The entire risk as the quality and performance of the program and data is with you. In no event will ACCA be liable to you for any damages, including without limitation any lost profits, lost savings, or other incidental or consequential damages arising out of the use or inability to use this program or the data. © 2011 Air Conditioning Contractors of America. All Rights Reserved. www.acca.org

ACCA, Manual J and Powered by ACCA Manual J are registered trademarks of the Air Conditioning Contractors of America. All rights reserved.

Cold weather humidification, or some lifestyles that produce excessive moisture, may cause condensation to occur if the absolute humidity of the indoor air is too high for the momentary circumstances. Condensation can occur on surfaces or concealed within the structure, and can lead to mold, mildew, frost damage, and moisture damage. The software does not perform calculations for the estimation or detection of possible condensation problems, and it is the designers (i.e. software users) responsibility to do so independently if required. For guidance and additional cautions refer to ACCA Manual J 8th Edition, including Section 1-11 and Section 27.

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.



Robert Borst
 Borst Engineering & Construction
 19000 E. Evans Creek Rd.
 Rogue River, OR 97537
 Phone: 541-826-7222
 Email: sunnyfallsrb@gmail.com

Manual J Worksheets

Manual J8 Load Calculation
 Project #: Sunny Falls Ranch
 June 19, 2015

Project Information

Project #: Sunny Falls Ranch Notes:
 Name: Passive Solar & HR Heated Residence
 Location: 19000 E. Evans Creek Rd., Rogue River, OR 97537

Form J1 (Summer)									
1	Name of Room		Passive Solar & HR Heated Residence				Entire House		
2	Running Feet of Exposed Wall		165						
3	Ceiling Height (Ft) and Gross Wall Area (SqFt)		9.7		2,189				
4	Room Dimensions (Ft) and Floor Plan Area (SqFt)		1,789						
5	Ceiling Slope (Deg.) and Gross Ceiling Area (SqFt)		1,789						
	Type of Exposure	Construction Number	Panel Faces	HTM		Area or Length	Btuh		
				Htg.	Ctg.		Heating	S-Ctg.	L-Ctg.
6a	Windows and Glass Doors	a	10Bf	S	21.12	34.41	727		
		b	1D-cf	E	21.56	49.79	1,073		
		c	1D-cf	N	16.66	9.89	165		
		d	1D-cf	S	21.56	200	4,302		
		e	1D-cf	N	21.56	29.95	646		
6b	Skylights	a							
7	Wood and Metal Doors	a	11P		12.76	66.67	851		
		b	11P		9.86	20.00	197		
8	Above Grade Walls and Partitions	a	14D-24		1.50	1,235	2,294		
		b	12A-0bw(Partition)			127	160		
		c	12E-5sw(Partition)			167	44		
		d	12E-5sw(Partition)			249	539		
9	Below Grade Walls	a							
10	Ceilings	a	16C-38ml			1,789	2,017		
11	Floors	a	22D-15-r		0.88	23 (F)	120		
		b	22D-15-r		0.89	38 (F)	291		
		c	22D-15-r		0.96	103 (F)	1,170		
		d	22D-15-r		1.16	32 (F)	130		
12	Infiltration	Heating Load (Btuh)		Effect ACH	0.140	WAR 1.0	1,816		
		Sensible Load (Btuh)							
		Latent Load (Btuh)							
13	Internal	a	Occupants at 230 and 200 Btuh			2			
		b	Scenario Number			Def			
		c	Default Adjustments						
		d	Custom Appliances						
		e	Plants						
Other		User specified additional loads							
14	Subtotals		Sum lines 6 through 13				16,541		
15	Duct Loads	EHLF & ESGF							
		ELG							
16	Ventilation Loads	Vent Cfm	101 / 0	E Cfm	101 / 0	2,270			
17	Winter Humidification Load	Gal/Day							
18	Piping Load								
19	Blower Heat								
20	AED Excursion								
21	Total Load	Sum lines 13 through 19				18,811			

Worksheet A					
Location And Design Conditions					
Location: (User Specified) Rogue River, Evans Creek Valley, Oregon		Elevation: 1,550 ft		Latitude: 42.4	
Indoor Conditions, Heating:	DB = 70.0 °F	RH = 35%	Indoor Conditions, Cooling:	DB = 75.0 °F	RH = 50%
Table 1 Conditions	99% DB = 26.0 °F	1% DB = 95.0 °F	Grains Difference = -13.7	Daily Range = High	
Design Temperature Differences		HTD = 44.0 °F		CTD = 20.0 °F	

Worksheet B										
HTM Values for Windows and Glass Doors										
Passive Solar & HR Heated Residence										
Panel	Const. Number	Internal Shade	Faces	U-Value	SHGC	Insect Screen	External Shading	Overhang	Heat HTM	Cool HTM
a	10Bf	BlindsMedium45(50%)	S	0.480	0.39	None	1.00	4 ft-1.5 ft Above	21.12	0.00
b	1D-cf	BlindsMedium45(50%)	E	0.490	0.56	None	1.00	4 ft-1.5 ft Above	21.56	0.00
c	1D-cf	BlindsMedium45(50%)	N	0.490	0.56	None	1.00	4 ft-1.5 ft Above	16.66	0.00
d	1D-cf	BlindsMedium45(50%)	S	0.490	0.56	None	1.00	4 ft-1.5 ft Above	21.56	0.00
e	1D-cf	BlindsMedium45(50%)	N	0.490	0.56	None	1.00	4 ft-1.5 ft Above	21.56	0.00

Worksheet C HTM Values for Skylights Passive Solar & HR Heated Residence												
Item	Const. Number	Internal Shading	Tilt	Faces	U-Value	SHGC	Description	Perimeter	Area	Ueff	Heating HTM	Cooling HTM

Worksheet D HTM Values and Net Area for Opaque Panels Passive Solar & HR Heated Residence													
Construction Number and Exposure Direction, or Ceiling Slope	HTD = 44.0 °F		CTD = 20.0 °F		Design Range = High			Heating HTM = U x HTD or U x PTDH Cooling HTM = U x CLTD or U x PTDC					
	Length (Ft)	Average Height/Width (Ft)	Gross Area (SqFt)	Opening Area (SqFt)	Net Area (SqFt)	Slab Edge (Ft)	U-Value or Slab F-Value 4A	HTD or PTDH	Group Number 4A	CLTD 4B or PTDC	Heating HTM	Cooling HTM	
Wood and Metal Doors													
a	11P	10	7	66.67				0.290	44.0		0.0	12.76	0.00
b	11P	3	7	20.00				0.290	34.0		0.0	9.86	0.00
Above Grade Walls													
a	14D-24	165	10	1,592	357	1,235		0.044	44.0	K		1.50	0.00
Partition Walls													
a	12A-0bw(Partition)	13	10	127		127		0.253	10.0	E		0.00	0.00
b	12E-5sw(Partition)	17	10	167		167		0.052	10.0	H		0.00	0.00
c	12E-5sw(Partition)	31	10	303	53.33	249		0.052	44.0	H		0.00	0.00
Below Grade Walls													
Ceilings													
a	16C-38ml			1,789		1,789		0.026	44.0			0.00	0.00
Passive Floors													
Radiant Floors													
a	22D-15-r			137			23	0.401	69.0			0.88	0.00
b	22D-15-r			327			38	0.401	69.0			0.89	0.00
c	22D-15-r			1,213			103	0.401	69.0			0.98	0.00
d	22D-15-r			112			32	0.401	59.0			1.16	0.00

Worksheet E Infiltration Loads										
HTD = 44.0 °F		CTD = 20.0 °F		Design Grains = -13.7		Elevation = 1,550 ft		Table 10A ACF = 0.93		
Step 1 - Table 8 Outdoor Air Requirement										
Operating Mode	Above Grade Volume AGV (CuFt)	Number of Bed Rooms	Number of People	Default Burner Btuh	Installed Burner Btuh	OA Cfm for 0.35 ACH	OA Cfm for People	OA Cfm for Furnace	Table 8 OA Cfm	
Heat	17,290		2	0		101	40	50	101	
Cool	0		2			0	40		101	
Step 2, Option 1 - Table 5 Defaults										
Operating Mode	Floor Area (CuFt)	Type of Const.	Space ACH	AGV (CuFt)	Space ICFM	Fireplace ICFM	Total ICFM		Table 8 OA CFM	Table 8 Vent CFM
Heating	1,789	Tight	0.14	17,290	40	0	40		101	101
Cooling		Tight	0.11	0	0		0			
Step 3 - Infiltration Loads on Central Equipment										
Type of Load	Worksheet H Value for Vent CFM	Exhaust CFM	CFM _{imb}	ICFM (Option 1)	Net Infil. CFM NCFM	H & C Loads (Btuh)				
Heat Load	101	101	0	40	40	1,816				
Sens Load										
Lat Load	0	0	0	0	0					
The room infiltration load equals the load on the central equipment multiplied by the gross wall area ratio (WAR) WAR = Gross room wall area / Gross wall area for all rooms served by the central equipment										

Worksheet F Internal Loads								
Source of Internal Load		Count	Sensible Factor (Btuh)	Latent Factor (Btuh)	Load Factor	Use Factor	Sensible Load	Latent Load
a	Occupants	2	230	200	1.0	1.0		
Total occupancy load for Form J1 (Btuh) =								
b	Default Scenario							
	Default (1,200 Btuh)	1			1.0	1.0		
Default scenario load for Form J1 (Btuh) =								
c	Adjustments to Default Scenario							
	None							
Total adjustment options for Form J1 (Btuh) =								
d	Individual Appliance Options							
	None							
Total individual appliance load for Form J1 (Btuh) =								
e	Plants							
	Small	0	10					
	Medium	0	20					
	Large	0	30					
Total plant load for Form J1 (Btuh) =								
Consider diversity; Load Factor = Average input / Rated or Nameplate Input; Use Factor = Percent operating time for one hour								

Worksheet H Ventilation Loads Passive Solar & HR Heated Residence										
Type of Load	VCFM or CFM _{disH}	SER LER for Heat Recovery Ventilator	Condition of Air Leaving Ventilation Dehumidifer	For VDH Only Indoor Grains for Site Elevation	Table 1 Outdoor Condition T _o and Grains	HTD and CTD From Wiksht A	LAT _{loss} LAT _{gain} V-Grains for Ventilation air	Site Elevation 1,550 Table 10A ACF	Ti Indoor Drybulb	Vent. Loads (Btuh)
Heat Load	101	0.5	LAT _{VDH}	Table 12	26.0 °F	44.0 °F	48.0	0.93	70.0	2,270
Sen Load	0	0.5	LAT _{VDH}		95.0 °F	20.0 °F			75.0	
Lat Load		0	0	Grain _{VDH}		-13.7		0.0		

Worksheet I											
Ancillary Loads											
Passive Solar & HR Heated Residence											
Winter Humidification Heating Load											
Indoor Conditions		Table 1 Values		Table 10A ACF	Table 12 Grains		Outdoor CFM			Humid H-Load (Btuh)	Gallons Per Day
Dy Bulb	Relative Humidity	Winter Dry Bulb	Site Elevation		Outdoor ODGR	Indoor IDGR	Net Infiltr. NCFM	Vent VCFM	Total TCFM		
70.0	35%	26.0	1,550	0.93	16.9	40.2	40	101	141		0.0
Heat of evaporation provided by central heating equipment. Heating Load = 0.68 x TCFM x (IDGR - ODGR) x ACF Humidification (RH Value) shall not cause visible or concealed condensation Gallons Per Day = 0.00272 x Heating Load (per Section 27 procedures).											
Hot Water Piping Load											
Size/Type	Feet of Pipe L _i	Water Temp. T _w °F	Ambient Temp. T _a °F	Wall TD WTD _i	Table 9 Factor F9 _i	Piping Load PL _i	WTD = T _w - T _a PL _i = 1.1 x L _i x WTD _i x F9 _i System Total (Btuh) = Sum PL _i				
							System Total				
Blower Motor Load											
Manufacturer's Sensible Capacity Data not Adjusted for Blower Heat	Blower Motor Power from Manufacturer's Blower Table			Default Power	Default Load	Sensible Load	Sensible Load = 3,413 x watts Sensible Load = 3,413 x KW Sensible Load = 3,600 x HP				
	Watts	KW	HP	Watts	Btuh	Btuh					
				0							
Moisture Migration Load											
Moisture will migrate through porous ceiling, wall, and floor materials that are not protected by a vapor retarding membrane. The latent moisture migration load for summer cooling may be an important issue if the structure does not have an appropriate vapor retarding membrane for the local summer climate. For winter humidification, moisture migration may cause visible or concealed condensation, mold, mildew, and structural damage. See the full version of Manual J, Section 28 for basic guidance. Contact the Energy Efficient Building Association (EEBA) for comprehensive guidance pertaining to membrane need and use. See the 2012 ASHRAE Handbook of Fundamentals, Chapter 25 and Chapter 26. Compare local code with EEBA/ASHRAE guidance. Incompatibilities require the attention of the local code authority. Joe Lstiburek is the primary authority on this issue (obtain contact info from the EEBA, ASHRAE, or internet search).											

Room Loads Passive Solar & HR Heated Residence		
Room	Heat Load (Btuh)	Sens Load (Btuh)
Master Bathroom Zone	1,197	
Master Bedroom Zone	2,911	
Great Room Zone	11,696	
Utility Room Zone	1,298	

*Average Load Procedure
Room loads do not include radiant panel back loss

Total Heating: 18,811 Total Sensible: 0 Total Latent: 0

Name	Heating	Sensible	Latent
Windows*	6,913	0	
Skylights*	0	0	
Doors	1,048	0	
Walls	3,038	0	
Below Grade Walls	0		
Ceilings	2,017	0	
Floors	0	0	
Infiltration	1,816	0	0
Internal		0	0
Duct Loads	0	0	0
Ventilation	2,270	0	0
Humidification	0		
Piping Load	0		
Radiant Backloss	1,710		
Recovered Backloss	0		
Blower Heat		0	
AED*		0	
Total Load	18,811	0	0
Total Area	1,789 ft²	0 ft²	

*Average Load Procedure, Glazing Area > 15% of floor area

Constructions

Walls

Code	Description	U-Value (btu/hr-ft ² -°F)
14D-24	Foam Concrete Matrix - R-22 to R-26; No Cavity Insulation; Plus Interior Finish	0.044
12A-0bw(Partition)	Frame Wall or Partition; Wood Framing; No Cavity Insulation; Brick Veneer; Plus Interior Finish	0.253
12E-5sw(Partition)	Frame Wall or Partition; Wood Framing; R-19 Insulation in 2 x 6 Stud Cavity; Stucco or Wood Siding; Plus Interior Finish	0.052

Doors

Code	Description	U-Value (btu/hr-ft ² -°F)
11P	Metal Door with Polyurethane Core	0.290

Floors

Code	Description	U-Value (btu/hr-ft ² -°F)
22D-15-r	22D - Vertical Board Insulation Covers Slab Edge, Turns Under the Slab and Extends Four Feet Horizontally, any Floor Cover	0.067

Ceilings

Code	Description	U-Value (btu/hr-ft ² -°F)
16C-38ml	FHA vented attic; No radiant barrier over ceiling or same type of air space behind an attic knee wall; Materials: Asphalt Shingles(s), Metal(m), Wood Shakes(w), Tar / Gravel(x), Membrane(z); Colors: Light(l), White(w);	0.026

Glazings

Windows

Code	Description	U-Value (btu/hr-ft ² -°F)
10Bf	French Door with Double Pane Clear Glass and Insulated Fiberglass Frame (SHGC = 0.39)	0.480
1D-cf	Double pane operable window or sliding glass door, with Clear Glass - Insulated Fiberglass Framing (SHGC = 0.56)	0.490

Disclaimers

With the permission of the Air Conditioning Contractors of America ("ACCA"), material is reproduced from Manual J Residential Load Calculation (8th Edition) which is copyrighted by ACCA. The program and data are provided "as is" without warranty of any kind either expressed or implied. The entire risk as the quality and performance of the program and data is with you. In no event will ACCA be liable to you for any damages, including without limitation any lost profits, lost savings, or other incidental or consequential damages arising out of the use or inability to use this program or the data. © 2011 Air Conditioning Contractors of America. All Rights Reserved. www.acca.org

ACCA, Manual J and Powered by ACCA Manual J are registered trademarks of the Air Conditioning Contractors of America. All rights reserved.

Cold weather humidification, or some lifestyles that produce excessive moisture, may cause condensation to occur if the absolute humidity of the indoor air is too high for the momentary circumstances. Condensation can occur on surfaces or concealed within the structure, and can lead to mold, mildew, frost damage, and moisture damage. The software does not perform calculations for the estimation or detection of possible condensation problems, and it is the designers (i.e. software users) responsibility to do so independently if required. For guidance and additional cautions refer to ACCA Manual J 8th Edition, including Section 1-11 and Section 27.

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.



Robert Borst
 Borst Engineering & Construction
 19000 E. Evans Creek Rd.
 Rogue River, OR 97537
 Phone: 541-826-7222
 Email: sunnyfallsrb@gmail.com

Heating System Summary

Project #: Sunny Falls Ranch
 June 19, 2015

Project Information

Project #: Sunny Falls Ranch
 Name: Passive Solar & HR Heated Residence
 Location: 19000 E. Evans Creek Rd., Rogue River, OR 97537

Notes:

Project Summary

Load Calculation Method:	Manual J8	Total Tubing Lengths:		Component Losses:	13,015 Btu/hr
Design Location:	(User Specified) Rogue River, Evans Creek Valley, Oregon	hePEX 1/2"	1,641 ft	Infiltration/Ventilation:	4,086 Btu/hr
Outdoor Temperature:	26.0 °F	Total RH Circuits:	8	Radiant Back Losses:	1,710 Btu/hr
Floorplans / Levels:		Total Manifolds:	1	Total Heating Load:	18,811 Btu/hr
Ground Floor	1,789 ft ²	Total Zones:	4	Radiant Heating:	17,101 Btu/hr
Total Area:	1,789 ft ²	Fluid Type:	100% Water	Radiant Back Losses:	1,710 Btu/hr
		Total Tubing Volume:	15.10 USG	Total Heating Load:	18,811 Btu/hr

Zone Heating Summary

Zone #	Area	Construction	Heating Types	RH Circuits	Total Tubing	Manifolds	Flowrate	Head Loss	RH Load	Supplemental	Total Load
101	1,213	Embedded Slab	RH	4	917	1	1.70	3.1	12,725	0	12,866
102	327	Embedded Slab	RH	2	428	1	0.46	1.0	3,202	0	3,202
103	137	Embedded Slab	RH	1	175	1	0.17	0.6	1,294	0	1,317
104	112	Embedded Slab	RH	1	120	1	0.19	0.5	1,427	0	1,427
Total	1,789	Embedded Slab	RH	8	1,641	1	2.52	3.1	18,811	0	18,811

Length = ft Area = ft² Temperature = °F Flowrate = USGPM Heat Loss = Btu/hr Unit Heat Loss = Btu/hr-ft² Rv = hr-ft²-°F/btu
 Head Loss = ft water RH = Radiant Floor Heating BB = Baseboard FA = Forced Air OTH = Other Heating SM = Snowmelt N = Not Heated

Created Using LoopCAD 2015 Uponor(US) (2/6/2016)
 Version: 15.0.0594

See end of report for important Notes and Disclaimers.

Room Heating Summary (By Construction Type)

Embedded Slab

Zone #	Room Name	Heating Type	Area	Heated Area	Manifold #	Tube Size	RH Circuits	Tube Spacing	Total Tubing	Floor Cover RV	Required Temp.	Unit RH Load	RH Load	Supplemental	Total Load
101	Great Room Zone	RH	1,213	901	Manifold 1	1/2	4	12	893	0.2	89	11	12,866	0	12,866
102	Master Bedroom Zone	RH	327	308	Manifold 1	1/2	2	12	415	0.2	84	10.4	3,202	0	3,202
103	Master Bathroom Zone	RH	137	58	Manifold 1	1/2	1	6	169	0.2	90	10.6	1,317	0	1,317
104	Utility Room Zone	RH	112	85	Manifold 1	1/2	1	12	114	0.2	81	14.3	1,427	0	1,427

RH Manifold Summary

Manifold Name	# Zones	# Circuits	Flowrate	Head Loss	Required Temp.	Supplied Temp.	Temp Drop	Manifold Type	Control Type	# Actuators
Manifold 1	4	8	2.52	3.1	90	93	15 (22)	Stainless-steel, 1" with flow meter, B&I, ball valve	Circuit	8
Total	4	8	2.52	3.1	90	-	-	-	-	8

Disclaimers

With the permission of the Air Conditioning Contractors of America ("ACCA"), material is reproduced from Manual J Residential Load Calculation (8th Edition) which is copyrighted by ACCA. The program and data are provided "as is" without warranty of any kind either expressed or implied. The entire risk as the quality and performance of the program and data is with you. In no event will ACCA be liable to you for any damages, including without limitation any lost profits, lost savings, or other incidental or consequential damages arising out of the use or inability to use this program or the data. © 2011 Air Conditioning Contractors of America. All Rights Reserved. www.acca.org

ACCA, Manual J and Powered by ACCA Manual J are registered trademarks of the Air Conditioning Contractors of America. All rights reserved.

Cold weather humidification, or some lifestyles that produce excessive moisture, may cause condensation to occur if the absolute humidity of the indoor air is too high for the momentary circumstances. Condensation can occur on surfaces or concealed within the structure, and can lead to mold, mildew, frost damage, and moisture damage. The software does not perform calculations for the estimation or detection of possible condensation problems, and it is the designers (i.e. software users) responsibility to do so independently if required. For guidance and additional cautions refer to ACCA Manual J 8th Edition, including Section 1-11 and Section 27.

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.



Robert Borst
 Borst Engineering & Construction
 19000 E. Evans Creek Rd.
 Rogue River, OR 97537
 Phone: 541-826-7222
 Email: sunnyfallsrb@gmail.com

Heating System Detail

Project #: Sunny Falls Ranch
 June 19, 2015

Project Information

Project #: Sunny Falls Ranch
 Name: Passive Solar & HR Heated Residence
 Location: 19000 E. Evans Creek Rd., Rogue River, OR 97537

Notes:

Design Conditions and Summary

Load Calculation Method:	Manual J8	Total Tubing Lengths:	Component Losses:	13,015 Btu/hr
Design Location:	(User Specified) Rogue River, Evans Creek Valley, Oregon	hePEX 1/2"	Infiltration/Ventilation:	4,086 Btu/hr
Outdoor Temperature:	26.0 °F	Total RH Circuits:	Radiant Back Losses:	1,710 Btu/hr
Floorplans / Levels:		Total Manifolds:	Total Heating Load:	18,811 Btu/hr
Ground Floor	1,789 ft ²	Total Zones:	Radiant Heating:	17,101 Btu/hr
Total Area:	1,789 ft ²	Fluid Type:	Radiant Back Losses:	1,710 Btu/hr
		100% Water	Total Heating Load:	18,811 Btu/hr
		Total Tubing Volume:		
		15.10 USG		

Zone Heating Summary

Zone #	Area	Heating Types	RH Circuits	Flowrate	Head Loss	Supplemental	Rooms
101	1,213	RH	4	1.70	3.1	0	Great Room Zone
102	327	RH	2	0.46	1.0	0	Master Bedroom Zone
103	137	RH	1	0.17	0.6	0	Master Bathroom Zone
104	112	RH	1	0.19	0.5	0	Utility Room Zone
Total	1,789	RH	8	2.52	3.1	0	

Length = ft Area = ft² Temperature = °F Flowrate = USGPM Heat Loss = Btu/hr Unit Heat Loss = Btu/hr-ft² Rv = hr-ft²-°F/btu
 Head Loss = ft water RH = Radiant Floor Heating BB = Baseboard FA = Forced Air OTH = Other Heating SM = Snowmelt N = Not Heated

Created Using LoopCAD 2015 Uponor(US) (2/6/2016)
 Version: 15.0.0594

See end of report for important Notes and Disclaimers.

Room Heating Summary

Ground Floor

Great Room Zone

Total Area: 1,213 ft²
 Heated by: RH
 Room Temperature: 70 °F
 Floor Covering (RV): 0.2 - Tile

Radiant Heating:
 Heated Area: 901 ft²
 Tubing in Floor: 917 ft
 Circuits in Room: 4
 Tube Spacing: 12
 Required Surface Temp: 76 °F
 Required Water Temp: 89 °F
 Est. Peak Output: 14,210 Btu/hr

Load/Loss Summary:
Room Design Load: 11,696 Btu/hr
 Radiant Load: 12,866 Btu/hr
 Baseboard Load: 0 Btu/hr
 Forced Air Load: 0 Btu/hr
 Other Load: 0 Btu/hr
 Radiant Back Loss: 1,170 Btu/hr
 Recovered Back Loss: 0 Btu/hr
 Total Heat Loss: 12,866 Btu/hr

Master Bathroom Zone

Total Area: 137 ft²
 Heated by: RH
 Room Temperature: 70 °F
 Floor Covering (RV): 0.2 - Tile

Radiant Heating:
 Heated Area: 58 ft²
 Tubing in Floor: 175 ft
 Circuits in Room: 1
 Tube Spacing: 6
 Required Surface Temp: 80 °F
 Required Water Temp: 90 °F
 Est. Peak Output: 1,345 Btu/hr

Load/Loss Summary:
Room Design Load: 1,197 Btu/hr
 Radiant Load: 1,317 Btu/hr
 Baseboard Load: 0 Btu/hr
 Forced Air Load: 0 Btu/hr
 Other Load: 0 Btu/hr
 Radiant Back Loss: 120 Btu/hr
 Recovered Back Loss: 0 Btu/hr
 Total Heat Loss: 1,317 Btu/hr

Master Bedroom Zone

Total Area: 327 ft²
 Heated by: RH
 Room Temperature: 70 °F
 Floor Covering (Rv): 0.2 - Tile

Radiant Heating:
 Heated Area: 308 ft²
 Tubing in Floor: 428 ft
 Circuits in Room: 2
 Tube Spacing: 12
 Required Surface Temp: 75 °F
 Required Water Temp: 84 °F
 Est. Peak Output: 4,311 Btu/hr

Load/Loss Summary:
Room Design Load: 2,911 Btu/hr
 Radiant Load: 3,202 Btu/hr
 Baseboard Load: 0 Btu/hr
 Forced Air Load: 0 Btu/hr
 Other Load: 0 Btu/hr
 Radiant Back Loss: 291 Btu/hr
 Recovered Back Loss: 0 Btu/hr
 Total Heat Loss: 3,202 Btu/hr

Outdoor Porch

Total Area: 125 ft²
 Heated by: NH
 Room Temperature: 26 °F
 Floor Covering (Rv): 0.0 - Unfinished Slab

Radiant Heating:
 Heated Area: 115 ft²
 Tubing in Floor: 0 ft
 Circuits in Room: 0
 Tube Spacing: 12
 Required Surface Temp: 26 °F
 Required Water Temp: 118 °F
 Est. Peak Output: 0 Btu/hr

Load/Loss Summary:
Room Design Load: 0 Btu/hr
 Radiant Load: 0 Btu/hr
 Baseboard Load: 0 Btu/hr
 Forced Air Load: 0 Btu/hr
 Other Load: 0 Btu/hr
 Radiant Back Loss: 0 Btu/hr
 Recovered Back Loss: 0 Btu/hr
 Total Heat Loss: 0 Btu/hr

Utility Room Zone

Total Area: 112 ft²
 Heated by: RH
 Room Temperature: 60 °F
 Floor Covering (Rv): 0.2 - Tile

Radiant Heating:
 Heated Area: 85 ft²
 Tubing in Floor: 120 ft
 Circuits in Room: 1
 Tube Spacing: 12
 Required Surface Temp: 68 °F
 Required Water Temp: 81 °F
 Est. Peak Output: 1,924 Btu/hr

Load/Loss Summary:
Room Design Load: 1,298 Btu/hr
 Radiant Load: 1,427 Btu/hr
 Baseboard Load: 0 Btu/hr
 Forced Air Load: 0 Btu/hr
 Other Load: 0 Btu/hr
 Radiant Back Loss: 130 Btu/hr
 Recovered Back Loss: 0 Btu/hr
 Total Heat Loss: 1,427 Btu/hr

Radiant Heating Details

Manifold Summary

Manifold Name	# Zones	# Circuits	Flowrate	Head Loss	Required Temp.	Supplied Temp.	Temp Drop	Manifold Type	Control Type	# Actuators
Manifold 1	4	8	2.52	3.1	90	93	15 (22)	Stainless-steel, 1" with flow meter, B&I, ball valve	Circuit	8
Total	4	8	2.52	3.1	90	-	-	-	-	8

Tubing Circuit Details

Manifold 1

Circuit	Rooms Served	Total Length	Tube Spacing	Area Covered	Tubing	Flowrate	Head Loss**	Temp Drop	Load	Actuator
A-1	Great Room Zone	242	12	250	hePEX 1/2"	0.48	2.9	15 (17)	3,572	Yes
A-2	Great Room Zone	219	12	212	hePEX 1/2"	0.40	2.0	15 (18)	3,025	Yes
A-3	Great Room Zone	232	12	206	hePEX 1/2"	0.39	2.0	15 (18)	2,946	Yes
A-4	Great Room Zone	224	12	223	hePEX 1/2"	0.43	2.2	15 (18)	3,182	Yes
A-5	Master Bedroom Zone	219	12	153	hePEX 1/2"	0.21	0.7	15 (22)	1,603	Yes
A-6	Master Bedroom Zone	209	12	166	hePEX 1/2"	0.24	0.8	15 (22)	1,762	Yes
A-7	Master Bathroom Zone	175	6	57	hePEX 1/2"	0.17	0.4	15 (17)	1,294	Yes
A-8	Utility Room Zone	120	12	85	hePEX 1/2"	0.19	0.3	15 (22)	1,427	Yes
Total	-	1,641		1,352	-	2.52	2.9		18,811	8

** Head loss for circuit tubing only

Disclaimers

With the permission of the Air Conditioning Contractors of America ("ACCA"), material is reproduced from Manual J Residential Load Calculation (8th Edition) which is copyrighted by ACCA. The program and data are provided "as is" without warranty of any kind either expressed or implied. The entire risk as the quality and performance of the program and data is with you. In no event will ACCA be liable to you for any damages, including without limitation any lost profits, lost savings, or other incidental or consequential damages arising out of the use or inability to use this program or the data. © 2011 Air Conditioning Contractors of America. All Rights Reserved. www.acca.org

ACCA, Manual J and Powered by ACCA Manual J are registered trademarks of the Air Conditioning Contractors of America. All rights reserved.

Cold weather humidification, or some lifestyles that produce excessive moisture, may cause condensation to occur if the absolute humidity of the indoor air is too high for the momentary circumstances. Condensation can occur on surfaces or concealed within the structure, and can lead to mold, mildew, frost damage, and moisture damage. The software does not perform calculations for the estimation or detection of possible condensation problems, and it is the designers (i.e. software users) responsibility to do so independently if required. For guidance and additional cautions refer to ACCA Manual J 8th Edition, including Section 1-11 and Section 27.

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.



Robert Borst
Borst Engineering & Construction
19000 E. Evans Creek Rd.
Rogue River, OR 97537
Phone: 541-826-7222
Email:sunnyfallsrb@gmail.com

Radiant Panel Schedule

Project #:Sunny Falls Ranch
June 19, 2015

Project Information

Project #: Sunny Falls Ranch
Name: Passive Solar & HR Heated Residence
Location: 19000 E. Evans Creek Rd., Rogue River, OR 97537

Notes:


Design Conditions and Summary

Load Calculation Method:	Manual J8	Component Losses:	13,015 Btu/hr
Design Location:	(User Specified) Rogue River, Evans Creek Valley, Oregon	Infiltration/Ventilation:	4,086 Btu/hr
Outdoor Temperature:	26.0 °F	Radiant Back Losses:	1,710 Btu/hr
Floorplans / Levels:		Total Heating Load:	18,811 Btu/hr
Ground Floor	1,789 ft ²	Radiant Heating:	17,101 Btu/hr
Total Area:	1,789 ft ²	Radiant Back Losses:	1,710 Btu/hr
		Total Heating Load:	18,811 Btu/hr

Radiant Panel Details

Panel Type #1 - Embedded Slab

Slab Thickness:	4.0 in
Tube Depth:	2.5 in
Slab R per Inch:	0.15 °F·ft ² ·hr/Btu·in
Spacing:	6 in, 12 in
Fastener:	2 Foam Staples
Floorplans:	
Ground Floor	1,707 ft ²



Note: Tube depth is measured from top of embedded layer to the centerline of the tubing.

Created Using LoopCAD 2015 Uponor(US) (2/6/2016)
Version:15.0.0594

See end of report for important Notes and Disclaimers.

Page 1 of 2

Disclaimers

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.



Robert Borst
 Borst Engineering & Construction
 19000 E. Evans Creek Rd.
 Rogue River, OR 97537
 Phone: 541-826-7222
 Email:sunnyfallsrb@gmail.com

Water Supply Summary

Project #:Sunny Falls Ranch
 June 19, 2015

Project Information

Project #: Sunny Falls Ranch
 Name: Passive Solar & HR Heated Residence
 Location: 19000 E. Evans Creek Rd., Rogue River, OR 97537

Notes:

Supply Summary

Name	Temp	Total Flow	Head Loss*	# Circuits	Load	# Zones
Water Temperature	93.0	2.52	3.1	8	18,811	4

* may contain additional head loss from manifold body and control valves

Water Temperature (93 °F)

Manifold 1 (93 °F, Stainless-steel, 1" with flow meter, B&I, ball valve, 8 Circuits)

Circuit	Rooms Served	Total Length	Tube Spacing	Area Covered	Tubing	Flowrate	Head Loss**	Temp Drop	Load	Actuator
A-1	Great Room Zone	242	12	250	hePEX 1/2"	0.48	2.9	15 (17)	3,572	Yes
A-2	Great Room Zone	219	12	212	hePEX 1/2"	0.40	2.0	15 (18)	3,025	Yes
A-3	Great Room Zone	232	12	206	hePEX 1/2"	0.39	2.0	15 (18)	2,946	Yes
A-4	Great Room Zone	224	12	223	hePEX 1/2"	0.43	2.2	15 (18)	3,182	Yes
A-5	Master Bedroom Zone	219	12	153	hePEX 1/2"	0.21	0.7	15 (22)	1,603	Yes
A-6	Master Bedroom Zone	209	12	166	hePEX 1/2"	0.24	0.8	15 (22)	1,762	Yes
A-7	Master Bathroom Zone	175	6	57	hePEX 1/2"	0.17	0.4	15 (17)	1,294	Yes
A-8	Utility Room Zone	120	12	85	hePEX 1/2"	0.19	0.3	15 (22)	1,427	Yes
Total	-	1,641	-	1,352	-	2.52	2.9	-	18,811	8

** Head loss for circuit tubing only

Disclaimers

With the permission of the Air Conditioning Contractors of America ("ACCA"), material is reproduced from Manual J Residential Load Calculation (8th Edition) which is copyrighted by ACCA. The program and data are provided "as is" without warranty of any kind either expressed or implied. The entire risk as the quality and performance of the program and data is with you. In no event will ACCA be liable to you for any damages, including without limitation any lost profits, lost savings, or other incidental or consequential damages arising out of the use or inability to use this program or the data. © 2011 Air Conditioning Contractors of America. All Rights Reserved. www.acca.org

ACCA, Manual J and Powered by ACCA Manual J are registered trademarks of the Air Conditioning Contractors of America. All rights reserved.

Cold weather humidification, or some lifestyles that produce excessive moisture, may cause condensation to occur if the absolute humidity of the indoor air is too high for the momentary circumstances. Condensation can occur on surfaces or concealed within the structure, and can lead to mold, mildew, frost damage, and moisture damage. The software does not perform calculations for the estimation or detection of possible condensation problems, and it is the designers (i.e. software users) responsibility to do so independently if required. For guidance and additional cautions refer to ACCA Manual J 8th Edition, including Section 1-11 and Section 27.

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.

Disclaimers

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.

Goods & Services Supplied

Other

Part Number	Description	Quantity	Unit	Price
NextGen-8	NextGen Electric Modulating Boiler with Outdoor Reset (20,478 Btu/h)	1	Ea	\$1,510.00

Subtotal: \$1,510.00

Fittings

Part Number	Description	Quantity	Unit	Price
Q4020500	1/2" ProPEX Fitting Assembly, R20 Thread	16	Ea	\$81.40
A2700802	Stainless-steel Manifold Assembly, 1" with flow meter, B&I, ball valve, 8 loops	1	Ea	\$400.73
A4020500	1/2" QS-style Compression Fitting Assembly, R20 thread	16	Ea	\$106.48

Subtotal: \$588.61

Tubing

Part Number	Description	Quantity	Unit	Price
A1220500	1/2" Wirsbo hePEX plus, 1,000 ft. coil	1	Ea	\$639.60
A1260500	1/2" Wirsbo hePEX, 500 ft. coil	1	Ea	\$319.83
A1250500	1/2" Wirsbo hePEX plus, 300 ft. coil	1	Ea	\$191.90

Subtotal: \$1,151.32

Controls

Part Number	Description	Quantity	Unit	Price
A3030524	Thermal Actuator for Stainless-steel Manifold, two-wire	8	Ea	\$277.20
A3601012	Zoning Base Unit (C-55), 12 Zones	1	Ea	\$341.17
A3601075	Zoning Interface (I-75)	1	Ea	\$223.85
A3600075	Zoning Thermostat (T-75), white	4	Ea	\$333.96
A3010100	Single-zone Pump Relay	1	Ea	\$80.19

Subtotal: \$1,256.37

Accessories

Part Number	Description	Quantity	Unit	Price
A7012000	2" Blue Foam Staples, 300/pkg.	3	Pkg	\$101.48
A5500500	3/4" PVC Elbow for 3/8" and 1/2" PEX Bend Support	16	Ea	\$30.80

Subtotal: \$132.28

Total Quote Price:

\$4,638.57

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.

Disclaimers

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.

NextGen™

BOILER

Just add PEX



The NextGen Boiler is the most modern and complete electric boiler on the market.

Engineered into one attractive plug-and-play system, it includes:

- *Stainless steel heat exchanger*
- *Circulating pump*
- *Expansion tank*
- *Air vent*
- *Safety relief valve*
- *User-friendly control panel*

Radiant floor heating has never been easier for the installer.

Just add PEX!

Just add PEX

STANDARD FEATURES

- UL listed
- 4 -14.4 kW output
- 13,652 - 49,147 BTU output
- Modulated three staged heating
- Temperature output 85°-140°F
- Stainless steel heat exchanger
- Wilo Star 21, three speed circulating pump
- Primary/secondary pump relay control
- Flat expansion tank housed inside the boiler
- Outdoor compensation/reset
- Redundant safety controls
- Automatic air vent
- Magnetic filter
- Low pressure cut off
- Off-peak capability

CONTROL PANEL FEATURES

- Inlet and outlet temperature readings
- Precise temperature control
- Flow rate reading (GPM)
- Pressure reading (psi)
- BTU output reading
- Fault code reading
- Pump exercise mode

WARRANTY INFORMATION

Kospel, S.A. warrants, and WH Response LLC carries out, the NextGen Boiler to the original purchaser to be free from manufacturing defects in materials and workmanship at the location of the original installation for a period of 26 months from the date of manufacture.

Air Vent

Manual high limit

Stainless steel heat exchanger

Auto reset high limit

Control panel

Flat expansion tank housed inside the boiler casing, on the back side.

Wilo circulating pump


Flow sensor

Differential bypass valve

Safety relief valve

Pressure sensor

Magnetic filter



NextGen Boiler: comparison to the competition

	NextGen BOILER	Competitors		
		1	2	3
Circulating Pump - Plumbed	✓			
Circulator Post/Purge Operation	✓		✓	
Circulating Pump Exerciser	✓			
Circulating Pump Switch with Auxiliary Relay	✓		✓	✓
Expansion Tank - Plumbed	✓			
Air Vent - Plumbed	✓			
30 psi Relief Valve - Plumbed	✓			✓
Pressure Differential Valve	✓			
Outdoor Compensation/Reset	✓		✓ upgrade	✓
Digital SWT Controller	✓			✓
External Diagnostic Lights	✓		✓	✓
Modulation	✓	✓	✓	✓
Digital Temperature Gauge	✓			
Digital Pressure Gauge	✓			
Off Peak Connections	✓	✓	✓	✓
Labor Savings	✓			
Heat Exchanger Material	Stainless Steel	Composite Plastic	Rolled Steel	Stainless Steel

Disclaimer: While WH Response LLC strives to make this information accurate, it can make no claims or guarantees of accuracy and expressly disclaims liability for errors and omissions in the comparisons.


WHY THE NEXTGEN BOILER?

While some radiant heating installations look like science projects gone wrong, the NextGen Boiler achieves a professional installation each and every time due to its innovative and compact design. The time saved on installation labor is attractive to both the contractor and the homeowner. The NextGen Boiler is manufactured to the highest standards and will exceed expectations for many years to come.



NextGen Boiler Ratings and Specifications

Model number	NextGen - 4	NextGen - 6	NextGen - 8	NextGen - 12	NextGen - 14.4
Boiler Rated Power	4 kW	6 kW	8 kW	12 kW	14.4 kW
	13,652 Btu/h	20,478 Btu/h	27,304 Btu/h	40,956 Btu/h	49,147 Btu/h
Voltage	240 V	240 V	240 V	240 V	240 V
Related Current	16.66 A	25.0 A	33.3 A	50.0 A	60 A
Breaker Quantity - Amps	1 @ 30 amp	1 @ 40 amp	1 @ 40 amp	2 @ 40 amp	2 @ 40 amp
Number of Heating Elements	3	3	3	3	3
Element Resistance / Each	43.3 Ω	28.8 Ω	21.6 Ω	14.4 Ω	12.0 Ω
Operating Temperature Range	85°-140° F				
Inlet / Outlet Pipe Thread	G 3/4" (internal thread)				
Expansion Vessel (14 psi.)	1.6 Gallons				
Safety relief valve rating	30 psi				
Maximum pressure	30 psi				
Minimum pressure	7 psi				
Weight	68.5 Lbs.				
Dimensions L x W x D	28" x 17" x 9 - 7/8"				
Minimum Flow Rate gpm	1.1	1.32			



Circulating pump - Wilo Star S 21 U 15.3 speed

Circulating pump voltage	120V, 60Hz
Circulating pump Amps	.97
Speeds	3 speed
Fuse rating	1.0 amp

WH Response, LLC
U.S. National Distributor

www.nextgenboiler.com
(844) 227-9977

info@nextgenboiler.com
6800 Electric Drive • Rockford, MN 55373

NextGenTM

BOILER

Just add PEX

The NextGen Boiler is an hydronic appliance that allows for consistent, professional installation for radiant heating applications. Take the complexity out of the mechanical room and replace it with peace of mind for the homeowner. All boiler parts and pieces (expansion tank, circulating pump, air vent, safety relive valve, and heat exchanger) are housed within the unit, for an aesthetically pleasing appearance.

Which would your customer prefer?



Traditional boiler
installation
Labor-intensive science project

vs.



NextGen Boiler
installation
Professional comfort system

Distributed by:

WH Response
A wholly owned subsidiary of Wright-Hempein Cooperative Electric Association

WH Response, LLC
U.S. National Distributor

www.nextgenboiler.com
(844) 227-9977

info@nextgenboiler.com
6800 Electric Drive
Rockford, MN 55373